SECURITON

ASD 531 Aspirating Smoke Detector

As of production version 311016 and FW version 01.01.xx

The ASD 531 aspirating smoke detector has the task of continuously taking air samples via a sampling pipe tube network from a monitored area and feeding the samples to a smoke sensor.

The ASD 531 consists of the detector housing and a sampling pipe tube network. The sampling pipe has several sampling holes whose size is such that each hole extracts the same amount of air. The sampling pipe may be I-, U-, T-, H-, or E-shaped. The sampling pipe is symmetrically designed in principle. Asymmetrical sampling pipe tube networks can also be implemented with the help of the "ASD PipeFlow" calculation software.



Fig. 1 ASD 531

Description

Integrated in the detector housing is a fan which, in conjunction with the sampling pipe, ensures an uninterrupted supply of air to the detector housing. Airflow monitoring detects any pipe blockages and pipe breakages in the sampling pipe.

The ASD 531 aspirating smoke detector is part of the ASD 535 product range and is available in a version for 1 sampling tube and 1 smoke sensor without smoke level indicator.

The **SSD 31** smoke sensor is used in the ASD 531. It has an alarm sensitivity range of 0.02%/m to 10%/m.

The ASD 531 aspirating smoke detector has two slots for additional modules. The following modules can be fitted:

- XLM 35 eXtended Line Module
- RIM 36 Relay Interface Module with 5 relays

The ASD 531 can be connected to a superordinate FACP by means of potential-free change-over contacts.


With the installation of an **XLM 35**, the ASD 531 can be ideally connected via the addressable loop to the SecuriFire and Integral fire alarm systems.

The **RIM 36** is available as a further installation option. This module enables the availability of all three pre-signal levels as well as the states of the smoke sensor and the sampling pipe. The ASD 531 aspirating smoke detector can be used for:

- Equipment monitoring: EDP systems, electrical distributors, switch cabinets, etc.
- Space monitoring: EDP rooms, ultra-clean rooms, warehouses, hollow floors, protection of cultural assets, transformer stations, prison cells, etc.

The ASD 531 can also be deployed in areas where normally conventional point detectors are used. Local regulations and provisions must be observed from case to case.

The response behaviour of the ASD 531 has been tested in compliance with EN 54-20, Class A, B and C.



- General
- Section 1 Section 4
- Planning Mounting
- Mounting Installation
- Section 6 Section 7

Section 5

- Commissioning Operation
 - n Section 8

Opening the detector housing




Press the **rotary snap locks** down <u>firmly</u> with a screwdriver (at least No. 5) toward the housing base and then **turn** 90° to open them. The position of the lock slit shows the current status:

- angled approx. 45° toward detector housing corner = closed;
- angled approx. 45° toward detector housing edge = open.

In either position the rotary snap locks $\underline{\textit{must}}$ snap into place.

Data sheet

Connection



Device connections on the AMB 31

The electrical connection is by means of plug-in terminals.

| Terminal | Signal | | |
|----------|----------------------------|---|--|
| 1 | +14 to +30 VDC ① | - Main power supply line | |
| 2 | 0 V | | |
| 3 | +14 to +30 VDC ① | - Redundant power supply line | |
| 4 | 0 V | Reduitdant power supply line | |
| 5 | + supply (for OC consur | ners) | |
| 6 | Output Fault, OC (all even | ents) | |
| 7 | Output Alarm, OC | | |
| 8 | Rel. 1 "(NO)" | Fault | |
| 9 | Rel. 1 "(NC)" | Contact (terminal 8/10) | |
| 10 | Rel. 1 "COM" | closed in idle state | |
| 11 | Rel. 2 "NO" | | |
| 12 | Rel. 2 "NC" | Alarm | |
| 13 | Rel. 2 "COM" | | |
| 14 | Input Reset external + | | |
| 15 | Input Reset external - | Opto-isolator input reset | |
| | UL/FM: +16.4 to +27 VD | DC | |

XLM 35, RIM 36 terminal assignment

The terminal assignments of the XLM 35 and RIM 35 can be found in the corresponding data sheets T 140 088 (XLM 35) and T 140 364 (RIM 36).

Wiring principle

Examples of and information on the wiring principle can be found in the Technical Description ASD 531, T 140 416, Sec. 6.

Using the smoke sensor

The ASD 531 ships with the smoke sensor already fitted. The smoke sensor has to be removed from the detector housing for the installation of the ASD (release the two lock clamps); however it should be left inside its protective packaging until the definitive commissioning. The definitive installation is carried out as described below, see **Fig. 3**.



 Always leave the smoke sensor inside its protective packaging until it is ready to be installed definitively in the detector housing.

- Depending on the situation (e.g. if there is a long time between mounting and commissioning or if the environment is extremely dusty (construction work) – only remove the smoke sensor from its protective packaging and insert it definitively in the detector housing when commissioning the ASD 531.
- Before installing the smoke sensor check that the insect protection screens are properly fitted to the smoke sensor chamber at the air inlet and outlet.
- The smoke sensor chamber must be absolutely free of any dirt and/or dust. Remove any residue resulting from mounting the detector housing.

Check the installation position when installing the smoke sensor. The connector plug of the smoke sensor must be face away from the slots of the additional modules. The anti-twist rib on the smoke sensor case prevents an incorrect installation position.

The smoke sensor is secured inside the ASD housing using the two lock clamps. Connect the ribbon cable supplied with the smoke sensor to the smoke sensor (large ribbon cable connector) and to the AMB 31 main board (small ribbon cable connector).

Data sheet




Fig. 3 Using the smoke sensor

Displays on the control unit

Several LEDs on the control unit indicate the current status of the ASD 531.

| Function / state | ueabo Operation | Alarm | Molle Fault | Det. dusty / dirty |
|---|--------------------|-------|-------------|--------------------|
| System Off (no voltage) | | | , | <u>,</u> |
| System inactive (reset external) | On | | ½ T | |
| Smoke sensor Off (from FACP) | On | | ½ T | |
| Quiescent state | On | | | |
| Pipe blockage/breakage, delay running | On | | 1 T | |
| Pipe blockage/breakage, fault triggered | On | | On | |
| Fan tacho signal missing | On | | On | |
| Fault triggered | On | | On | |
| Pre-signal 1 | On | 2 T | | |
| Pre-signal 2 | On | 1 T | | |
| Pre-signal 3 | On | ½ T | | |
| Alarm | On | On | | |
| Smoke sensor filter fault | On | | | 2 T |
| Smoke sensor dusty | On | | | <mark>1 T</mark> |
| Smoke sensor dirty | On | | | <mark>1∕₂ T</mark> |
| Smoke sensor fault | On | | | On |
| Lamp test (press "Reset" 10 s) | On | 1 T | 1 T | 1 T |

1 No fault triggered (triggers only after delay time has expired → "Fault" continuously lit).

T = flashing display; 1/2 s cycle / 1 s cycle / 2 s cycle

Indicators on the AMB 31 main board

Various auxiliary LEDs are on the AMB 31 and have the following meaning:

- LED "Class" and "Holes" flash = invalid constellation of rotary • switches "Class" and "Holes";
- LED "Mode" = various functions;
- LED "WDog" = watchdog indicator; •
- LED CardOk = SD memory card present •
- LED Com = communication with the SD memory card.
- LED 2 (yellow) flashing = filter replacement started; • •
- LED 4 (green) continuously lit = filter monitoring "On".

Switch positions of rotary switch "Mode"

Programming

The ASD 531 has several switch positions that are configured with permanently assigned parameters:

- System limits according to EN 54-20, Class A to C, without using "ASD PipeFlow", positions A/1 to C/C;
- System limits for saving the settings after using • "ASD PipeFlow", positions 1/1 to 3/F.

| Pos. | Purpose |
|--|--|
| 0 | Initial reset |
| 1 | Operation position |
| 2 | Isolate device |
| 3 | Test trigger fault |
| 4 | Test trigger pre-signal |
| 5 | Test trigger alarm |
| 6 | Log off optional module |
| 7 | Device inactive |
| 8 | Filter monitoring On/Off, filter replacement |
| 9 | Read out / change filter service life |
| A – F | Reserve |
| for the second s | The table lists only the available switch positions. For in- ormation about the input procedure please refer to Technical Description T 140 416, Sec. 8.3. |

System limits without ASD PipeFlow calculation

The system limits apply to the planning without using the ASD PipeFlow calculation software. There are two areas, with the following meaning:

Detector sensitivity

Rotary switch "Class", switch positions A to C; Rotary switch "Holes", switch positions 1 to C;

Air flow tolerance and delay time DIP switch "Airflow", switch positions 1 to 4.

Detector sensitivity

The desired alarm class according to EN 54-20 is set on the "Class" rotary switch. The switch position corresponds to the class (switch position A = response grade A).

The total number of sampling holes is set on the "Holes" rotary switch (**A** = 10, **C** = 12).

Air flow tolerance and delay time

The air flow tolerance and delay time are set on the "Airflow" DIP switch:

| Switch 1 | Switch 2 | Air flow tolerance |
|----------|----------|--------------------|
| OFF | OFF | ±20% ① |
| OFF | ON | ±30% |
| ON | OFF | ±50% |
| ON | ON | ±10% |

| Switch 3 | Switch 4 | Delay time |
|----------|----------|------------------------|
| OFF | OFF | 300 s (5 min) ① |
| OFF | ON | 10 min |
| ON | OFF | 20 min |
| ON | ON | 10 s (test position) ② |



 For a normative system the setting ±20% / 300 s is required. Other values are <u>not</u> EN tested and may be used only after consulting with the manufacturer.
 This setting may be used only for test purposes; it is


Inis setting may be used only for test purposes; it is not permitted in normal operation.

System limits for planning without "ASD PipeFlow" calculation

| Shape | Length from ASD to the last T-piece/cross | Max. length from ASD to farthest sampling hole | Number of sampling holes per sampling branch | Max. overall length of the sampling pipe |
|-------|---|--|---|--|
| I | | 30 m | 1 – 7 | 30 m |
| U/T | 1 – 10 m | 30 m | 1 – 6 | 55 m |
| Н | 1 – 10 m | 20 m | 1 – 3 | 55 m |
| E | 1 – 10 m | 20 m | 1 – 4 | 55 m |

Sampling holes for planning with ASD PipeFlow calculation

The tables below show the corresponding hole diameters for the numbers in **Fig. 4** depending on the number of sampling holes per sampling branch.



| I-shaped sampling pipe | | | | | | | |
|--------------------------------------|--|-----|-----|-----|-----|-----|-----|
| Number of samp- ling holes in the | Hole diameter in mm for the sampling hole number from the ASD | | | | | | |
| sampling branch | 1 | 2 | 3 | 4 | 5 | 6 | 7 |
| 1 | 7.0 | | | | | | |
| 2 | 5.5 | 7.0 | | | | | |
| 3 | 5.0 | 5.5 | 7.0 | | | | |
| 4 | 4.5 | 4.5 | 5.5 | 7.0 | | | |
| 5 | 4.0 | 4.5 | 5.0 | 5.0 | 6.5 | | |
| 6 | 3.5 | 3.5 | 3.5 | 3.5 | 4.0 | 5.5 | |
| 7 | 3.5 | 3.5 | 3.5 | 3.5 | 4.0 | 4.0 | 5.5 |

| U/T-shaped sampling pipes | | | | | | |
|-----------------------------------|--|-----|-----|-----|-----|-----|
| Number of samp- ling holes per | Hole diameter in mm for the sampling hole number from the ASD | | | | | |
| sampling branch | 1 2 3 4 5 6 | | | | 6 | |
| 1 | 7.0 | | | | | |
| 2 | 5.0 | 6.5 | | | | |
| 3 | 4.5 | 5.0 | 7.0 | | | |
| 4 | 3.5 | 4.0 | 4.0 | 6.5 | | |
| 5 | 3.0 | 3.0 | 3.0 | 3.0 | 5.5 | |
| 6 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 | 5.5 |

| H-shaped sampling pipes | | | | | |
|-----------------------------------|--|-----|--|--|--|
| Number of samp- ling holes per | Hole diameter in mm for the sampling hole number from the ASD | | | | |
| sampling branch | 1 2 3 | | | | |
| 1 | 7.0 | | | | |
| 2 | 3.5 | 6.5 | | | |
| 3 | 2.5 2.5 6.5 | | | | |

| E-shaped sampling pipes | | | | | |
|-----------------------------------|--|-----|-----|-----|--|
| Number of samp- ling holes per | Hole diameter in mm for the sampling hole number from the ASD | | | | |
| sampling branch | 1 2 3 4 | | | | |
| 1 | 7.0 | | | | |
| 2 | 4.5 | 7.0 | | | |
| 3 | 3.0 | 3.0 | 6.0 | | |
| 4 | 2.5 | 2.5 | 2.5 | 6.0 | |

Relay latching:

A latching function for various signals can be switched on on the "Relay" DIP switch.

| Signal | Switch position ③ | Default Setting | Range | |
|---|----------------------|--------------------|----------|--|
| Alarm | 1 | On | On / Off | |
| • Fault ① | 2 | On | On / Off | |
| Pre-signal ② | 3 | Off | Off / On | |
| ① If a RIM 36 is built in, also for relays 4 + 5. | | | | |

```
() If a RIM 36 is built in, also for relays 4 + 3.
(2) If a RIM 36 is built in, also for relays 1 - 3.
```

③ Switch position 4 has no function.

RIM 36 relay assignment:

| Relay | Signal |
|---------|---------------------------------------|
| Relay 1 | Pre-signal 1 smoke sensor |
| Relay 2 | Pre-signal 2 smoke sensor |
| Relay 3 | Pre-signal 3 smoke sensor |
| Delaur | dirt / dust / fault |
| Relay 4 | smoke sensor |
| Relay 5 | Sampling tube blockage / interruption |
| Relay 5 | fan fault |

Commissioning

When commissioning the ASD 531, it is necessary to perform an initial reset to automatically adjusting the airflow monitoring on the connected sampling pipe.

If the ASD 531 is operated without "ASD PipeFlow" calculation, the commissioning can be carried out directly using the "BasiConfig" process.

In projects in which the "ASD PipeFlow" calculation software was used, the switch settings "1/1" to "3/F" are to be applied.

Starting up



Before the ASD 531 is switched on, make sure all the precautions required for its operation have been taken (see also T 140 416, Sec. 7.1).

- Sampling pipe correctly laid and connected;
- Smoke sensor removed from protective packaging, built in and connected;
- Isolation strip on the lithium battery (AMB 31) removed.

Startup sequence and procedure:

- 1. Switch on supply voltage (FACP); the next procedure can be carried out while the fan is ramping up to its definitive speed (takes about 100 s). The system is immediately armed for alarm.
- 2. "BasiConfig": Set the required response grade and the number of sampling holes (e.g. "B/6") → see also "Re-programming".
 or:

Select corresponding "**ASD PipeFlow**": values (Technical Description ASD 531, T 140 416, Sec. 4.3.1). Set rotary switch.

- Following a minimum waiting time of 2 min after switching on, an initial reset must be performed (possible only via AMB 31) → see "*Initial reset*".
- **4.** The ASD 531 is now ready for operation.

Re-programming

Example: Response grade B, sampling holes 6, airflow tolerance / delay time $\pm 30\%$ / 600 s \oplus .

| Measure | | Indicator @ | Procedure Remark | |
|---------|---|-------------|---|--|
| 1. | Turn rotary switch "Class" to position " B " | | Set response grade B | |
| 2. | Turn rotary switch "Holes" to position " 6 " | | Set 6 sampling holes | |
| 3. | Set DIP switch "Air- flow": Positions "1" and "3" on "OFF"; Positions "2" and "4" on "ON; | | Set airflow tolerance / delay time ±30% / 600 s ① | |

① For normative systems the setting ±20% / 300 s is required. Other values are <u>not</u> EN tested and may be used only after consulting with the manufacturer.

② The "Class" and "Holes" LEDs begin to flash after a delay time when there is an invalid entry (e.g. Class A with 10 sampling holes).

Initial reset

Me

| easure |) | | Ind | icat | or | | | roceo | |
|--------|--------|---------|------|------|---------|------|------------|-------|--------|
| | Refore | perform | nina | an | initial | roce | ` † | oftor | cowite |

Before performing an initial reset after switching on the ASD 531, a **waiting time of at least 2 min** must be observed.

| 1. | Turn rotary switch "Mode" to position " 0 " | | Switch position initial reset |
|----|--|---|---|
| 2. | Press key "Set/Res" | | Initial reset in pro- gress |
| 3. | Wait | Both middle LEDs of the air flow indicator are lit | Initial reset comple- ted |
| 4. | Turn rotary switch "Mode" to position "1" | | Operation switch po- sition |
| 5. | Press key "Set/Res" | | Operating mode running |

Filter replacement

When filter monitoring is activated and after expiry of the configured filter service life, a "Filter fault (service life exceeded)" fault is triggered. To remedy, the filter element in a filter-box or dust filter unit must be replaced.



For an activated filter replacement the ASD is set to the "isolate" state. This insures that during the replacement work falling dust particles from the filter element do not

cause a false alarm. When the ASD 531 housing is closed, the "Start filter replacement" function can be activated by means of the "**Reset**" key (provided the filter function is activated). To do so, press the key **longer than 15 s** (attention: lamp test after 10 s). After 15 s the filter replacement is started and indicated by switching to the "Isolate" state (LED "Fault").

After the filter has been replaced, the "Filter replacement" procedure is completed by pressing the "**Reset**" **key** on the ASD. This cancels the "Isolate" state and resets the fault on the ASD. "Filter service life" monitoring is restarted at 0.

The filter replacement can also be started via *BasiConfig* rotary switch "Mode", position **8**. For information please refer to Technical Description T 140 416, Section 7.8.

Measurements / commissioning protocol

- Carry out the following measurements:
- Measure voltage at terminals 1 (+), 2 (-) (also terminals 3 and 4 if redundant supply) → target value = 17.6 to 27.6 VDC
- Airflow value based on the LED bar (see Technical Description, T 140 416, Sec. 7.6.1).

The commissioning protocol is like a personal history of the ASD 531 and should therefore be filled out conscientiously and completely and stored in the ASD 531. If required, a copy can be made and stored in the system dossier.

Data sheet

Checking fault and alarm release

| Test | Procedure | Action |
|-----------------------------|--|--|
| | or switch off fire the superordina | e incident control and remote alert- te FACP. |
| Check airflow monitoring | Tape over the sampling ho- les (adhesive tape); the number de- pends on the pipe configu- ration. | As soon as the resulting change in the airflow is exceeded by ±20%, the "Fault" LED begins to flash. Once the LS-Ü delay (300 s) has elapsed, the ASD triggers a fault → fault on FACP ①. |
| Check alarm release | Impose smoke at the maintenance sampling hole or sampling hole. | ASD triggers an alarm → alarm on FACP; check for cor- rect alarm transmission (zone/ range release) on the FACP^①. Any pre-signals will also re- lease. |


 Reset the ASD 531 between each check (please note: resetting the ASD does not reset the FACP).

> 13 195

Article numbers / Spare parts

| Short designation | | Article number |
|--------------------------|----------------------|------------------|
| Aspirating Smoke Deter | ctor ASD 531 | 11-2000002-01-XX |
| Replacement smoke se | nsor SSD 31 | 11-2200009-01-XX |
| eXtended Line Module | XLM 35 | 11-2200003-01-XX |
| RIM 36 Relay Interface | Module | 11-2200005-01-XX |
| SD memory card (indus | trial version) | 11-4000007-01-XX |
| AMB 31 Main Board | | 11-2200012-01-XX |
| Aspirating Fan Unit AFL | J 32, complete | 11-2200008-01-XX |
| Air Flow Sensor AFS 32 | 2 | 11-2200007-01-XX |
| Insect Protection Scree | n IPS 35 (set of 2) | 11-2300012-01-XX |
| Lithium battery | | 11-4000002-01-XX |
| Cable screw union | M20 (set of 10) | 11-4000003-01-XX |
| | M25 (set of 10) | 11-4000004-01-XX |
| Adapter US cable screv | v union AD US M-Inch | 11-2300029-01-XX |
| UMS 35 Universal Mod | ule Support | 4301252.0101 |
| Technical description A | SD 531 | T 140 416 |
| Material for the samplin | g pipe | T 131 194 |
| Commissioning protoco | 1 | T 140 418 |
| Data sheets | XLM 35 | T 140 088 |
| | RIM 36 | T 140 364 |
| AFU 32 installation inst | ructions | T 140 426 |
| | | |

154



27

→ I40 Fig. 5 Detector housing dimensioned drawing

Dimensioned drawing

Technical data

| Туре | | ASD 531 | | | |
|---|--|---------------------------------------|--------------|--|--|
| Supply voltage range | 14 to 30 (| 4 to 30 (UL/FM = 16.4 to 27) | | | |
| Maximum power consumption, | | typical | | | |
| measured at -> | 14 VDC ① | 24 VDC | | | |
| ASD 531 Quiescent / fault | approx. 110 | approx. 75 | mA | | |
| Alarm | approx. 120 | approx. 80 | mA | | |
| additionally with RIM 36 | approx. 30 | approx. 15 | mA | | |
| additionally with XLM 35 | approx. 15 | approx. 5 | mA | | |
| Switch-on current peak 2 (caused by EMC protection elements on the ASD su | pply input) | approx. 5 | А | | |
| | | for max. 1 | ms | | |
| Sampling pipe length | | see T 140 416 | , Sec. 4.2.1 | | |
| Sampling pipe diameter, typical (inner/outer) | | Ø 20 / 25 | mm | | |
| Max. number of sampling holes | | see T 140 416 | , Sec. 4.2.1 | | |
| Sampling hole diameter | Ø 2 / 2.5 / 3 / 3.5 / 4 / 4. | 5 / 5 / 5.5 / 6 / 6.5 / 7 | mm | | |
| Response range | EN | 54-20, Class A, B, C | | | |
| Protection type compliant with IEC 529 / EN 60529 | | | | | |
| Ambient conditions compliant with IEC 721-3-3 / EN 60721-3-3 | | 3K5 / 3Z1 | class | | |
| Extended ambient conditions: | | | | | |
| Detector housing temperature range | -10 - | - +55 (UL max. +40) | °C | | |
| Sampling pipe temperature range | | -10-+55 ^③ | °C | | |
| Max. permissible temperature fluctuation in detector housing and sampli | ng pipe operation | 20 ③ | °C | | |
| Max. permissible storage temperature for detector housing (without conc | densation) | -20 - +70 | °C | | |
| Ambient pressure difference between detector housing and sampling pip | id sampling pipe (sampling holes) must | | | | |
| Humidity ambient condition for detector housing (transient without conde | ensation) | 95 ③ | % rel. h | | |
| Humidity ambient condition (continuous) | | 70 3 | % rel. h | | |
| Max. loading capacity, relay contact | | 50 (UL max. 30) | VDC | | |
| | | 1 | A | | |
| | | 30 | W | | |
| Max. loading capacity per OC output (dielectric strength 30 VDC) | | 50 | mA | | |
| Plug-in terminals | | 2.5 | mm² | | |
| Cable entry for cable Ø | Ø 5 – 12 (M | 20) / Ø 9 – 18 (M25) | mm | | |
| Noise level min. | | 24.5 | dB (A) | | |
| max. | | 27.0 | dB (A) | | |
| Housing material | | BS blend, UL 94-V0 | | | |
| colour | grey 280 70 05 / anthracite violet 300 20 05 | | | | |
| Approvals EN 54-20 / EN 54-27 / | / FM 3230-3250 / UL 268 / l | JL 268A / ULC-S529 | | | |
| ASD 531 dimensions (W x H x D) | | 195 x 333 x 140 | mm | | |
| Weight ASD 531 | | 1,950 | g | | |

① Power consumption at maximum permitted voltage drop in the electrical installation (decisive value for calculating the conductor cross-section).

② May cause the protective circuit to trigger immediately in the case of power supplies with overload protective circuits (primarily in devices with no emergency power supply and output current of < 1.5 A).</p>

③ Lower or higher temperature ranges are also possible subject to consultation with the manufacturer. The manufacturer must be consulted if the device is used in the condensation range.

Changes to Index a on pages: 2, 3, 3, 3, 3, 4, 4, 4, 5, 5, 6, 7

ASD 531